5th APRIL 2018

Secta Reference: SR18941

ATTN: Firstyle Homes Pty Ltd

P.O. Box 171

HOXTON PARK NSW 2171



ABN 91 136 407 835

Secta Consulting Engineers Pty Ltd PO Box 259 Condell Park NSW 2200 Head Office - (02) 9707 3414 web: www.sectaengineering.com.au email: office@sectaeng.com.au site off: Milperra, Penrith, Kellyville, Central Coast

Following your request, we can confirm that the following site has been inspected and subsequently classified by Secta Consulting Engineers in accordance with the relevant standards.

SITE REPORT

Re: Proposed Residential Property

LOT 3097 HARRIER PLACE CLAREMONT MEADOWS

Client: FIRSTYLE HOMES

Slab Design Code: SD4 -300pod(house) 225pod (garage), SL82

Referenced Code - AS 2870

Procedure's: Bore test hole sample < 50mm diameter.

Visual inspection.

Identification of Soil Profile.

Referenced Material

Basic Site Profile: Topsoil / Clay / Rock

Wind Classification: "N2 (W33N)" in accordance with "AS 4055-2006"

Durability Classification: "Exterior"

Concrete Quality: 32 Mpa (Salinity Parameters)

References: AS 2870 – 2011 "Code for Residential Slabs and footings".

Classification for N.S.W Soils for Housing.

(NSW Builders Licensing Board)

AS 4055-2006 Wind Loads for Housing

AS/NZS 4456.10:2003 Masonry units and segmental pavers and flags - Methods of test - Determining resistance to salt attack.

This report shall not be construed as relieving any other party of their responsibilities or contractual obligations.

Yours sincerely



Sharief Abdelfattah MIEAUST CPENG NPER (structural/civil) Accredited Certifier (structural/civil)

for Secta Consulting Engineers



5th APRIL 2018

Secta Reference: SR18941

ATTN: Firstyle Homes Pty Ltd

P.O. Box 171

HOXTON PARK NSW 2171



ABN 91 136 407 835

Secta Consulting Engineers Pty Ltd PO Box 259 Condell Park NSW 2200 Head Office - (02) 9707 3414 web: www.sectaengineering.com.au email: office@sectaeng.com.au site off: Milperra, Penrith, Kellyville, Central Coast

Following your request, we can confirm that the following site has been inspected and subsequently classified by Secta Consulting Engineers in accordance with the relevant standards.

SITE REPORT

Re: Proposed Residential Property

LOT 3097 HARRIER PLACE CLAREMONT MEADOWS

Client: FIRSTYLE HOMES

Slab Design Code: SD4 -300pod(house) 225pod (garage), SL82

Referenced Code - AS 2870

Procedure's: Bore test hole sample < 50mm diameter.

Visual inspection.

Identification of Soil Profile. Referenced Material

Referenced Materia

Basic Site Profile: Topsoil / Clay / Rock

Wind Classification: "N2 (W33N)" in accordance with "AS 4055-2006"

Durability Classification: "Exterior"

Concrete Quality: 32 Mpa (Salinity Parameters)

References: AS 2870 – 2011 "Code for Residential Slabs and footings".

Classification for N.S.W Soils for Housing.

(NSW Builders Licensing Board)

AS 4055-2006 Wind Loads for Housing

AS/NZS 4456.10:2003 Masonry units and segmental pavers and flags - Methods of test - Determining resistance to salt attack.

This report shall not be construed as relieving any other party of their responsibilities or contractual obligations.

Yours sincerely



Sharief Abdelfattah MIEAUST CPENG NPER (structural/civil) Accredited Certifier (structural/civil)

for Secta Consulting Engineers

