

### **LEGEND**

**EMERGENCY EXIT** 



**EMERGENCY EXIT** 



FIRE EXTINGUISHER (DRY POWDER) (ABE)



FIRE HOSE REEL (FHR)



PRIMARY EXIT ROUTE



FIRST AID KIT



ASSEMBLY AREA





## TYPICAL EGRESS SIGNAGE

NOT TO SCALE

#### FIRE EXTINGUISHERS AND HOSE REELS

IF SAFE TO DO SO: FIRE EXTINGUISHERS

SELECT THE CORRECT EXTINGUISHER

1. REMOVE FROM BRACKET 2. CARRY TO SCENE OF FIRE.

3. WHILST CLEAR OF FIRE REMOVE PIN AND TEST THE EXTINGUISHER.

4. PROCEED TO AIM (INITIALLY FROM A DISTANCE OF NO CLOSER THAN 2 METRES) DIRECT AGENT AT BASE OF FIRE.

FIRE HOSE REEL 1. OPEN VALVE (ENSURE THAT HOSE REEL IS TURNED OFF A)T NOZZLE).

2. RUN OUT HOSE TOWARDS SCENE OF FIRE. 3. OPEN NOZZLE AND DIRECT STREAM AT BASE OF FIRE.

NB.FIRE HOSE REELS ARE NOT TO BE USED ON FIRES WITH AN ELECTRICAL

#### BOMB OR SUBSTANCE THREAT PROCEDURES

1. REMAIN CALM .. 2. RECORD EXACT WORDING OF THREAT. 3. KEEP THE CALLER TALKING - TRY TO OBTAIN AS MUCH INFORMATION AS POSSIBLE USING THE THREAT CHECKLIST. 4. REPORT CALL TO: CHIEF WARDEN, YOUR MANAGEMENT AND POLICE ON "000". 5. RECORD DETAILS OF CALLER'S VOICE AND BACKGROUND NOISE . 6. AWAIT INSTRUCTIONS FROM AUTHORISED

PERSONS.


## **EVACUATION PROCEDURES**

IF IN IMMEDIATE DANGER OR ON BEING INSTRUCTED TO EVACUATE

1. IF SAFE TO DO SO SECURE YOUR OFFICE AND EVACUATE THE BUILDING VIA THE NEAREST EXIT AND PROCEED IN AN ORDERLY MANNER TO THE ASSEMBLY AREA.

2. DO NOT RE-ENTER THE BUILDING UNLESS ADVISED IT IS SAFE TO DO SO BY AN AUTHORISED PERSON.


Issue	Description	Date	Drawn	Issued
Α	ISSUED FOR DA	16.09.2019	VP	CZ
В	RE ISSUED FOR DA	29.07.2019	VP	CZ
С	RE ISSUED FOR DA	01.08.2019	VP	CZ



 All dimensions and floor areas are to be verified by the Builder prior to the commencement of any building work. Any discrepancies are to be brought to the attention of the designer. 2) Levels shown are approximate unless accompanied by reduced levels.

4) All boundary clearances must be verified by the surveyor prior to commencement of any building work. 5) Where engineering drawings are required such must take preference to this drawing. 6) Stormwater to be discharged to Councils' requirements and AS 3500.3-1990. 7) All services to be located and verified by the Builder with relevant authorities before any building

This design and the associated documents is subject to copyright laws and may not be reproduced in any form without written consent from Algorry Zappia & Associates Pty Ltd.



# ALGORRY ZAPPIA & ASSOCIATES PTY. LTD. Proje Building Designers & Consulting Civil & Structural Engineers a Suite 4, Level 1, 84 Bathurst Street, Liverpool, NSW 2170

P.O. Box 825, Liverpool Business Centre, NSW 1871 9602 3133 / 9602 0303 e admin@algorryzappia.com.au www.algorryzappia.com.au

, <b>() — ()</b> FI7. LID.	1 1001 0
5	LOT 1 & 2 THIRLMER
	Client TM & N
ABN 43 064 952 692	FIRE E

Project  PROPOSED CHILDCARE CENTRE  LOT 1 & 2 IN DP 1230557 No.s 2 & 6 CHALKER STREET  THIRLMERE	Drawn <b>VP</b>	Checked <b>CZ</b>	Date JULY 2019
TM & NH & BH VO	Activity Type  DA	Job # 1026-19	Scale @ A1 AS SHOWN
FIRE EGRESS PLAN	Project # <b>P5399</b>	Sheet # A07	Issue <b>C</b>